

IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION **IEC Certification Scheme for Explosive Atmospheres**

| Ca | rtif | ca | ta | NIO | |
|----|------|----|----|-----|--|

IECEx BKI 11.0004X

issue No :0

Certificate history

Current

Date of Issue:

2011-07-06

Page 1 of 3

Applicant:

NIVELCO Process Control Co. H-1043 Budapest, Dugonics utca 11. Hungary Hungary

Electrical Apparatus: Optional accessory:

Universal display and controller unit MULTICONT P**-2**-* Ex

Type of Protection:

General requirements, Intrinsic safety

Marking

[Ex ia Ga] IIB -20 °C ≤ Tamb ≤ +50 °C

Approved for issue on behalf of the IECEx Certification Body:

János Feies

managing director

Signature: (for printed version) Date:

This certificate and schedule may only be reproduced in full.
 This certificate is not transferable and remains the property of the issuing body.
 The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by

Testing Station for Explosion Proof Equipment H 1037 BUDAPEST MIKOVINY S.u. 2-4







IECEx Certificate of Conformity

Certificate No.

IECEY BKI 11 0004X

Issue No.: 0 Page 2 of 3

Date of Issue: Manufacturer:

NIVELCO Process Control Co. H-1043 Budapest, Dugonics utca 11. Hungary

2011-07-06

Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2007-10 Explosive atmospheres - Part 0:Equipment - General requirements

IEC 60079-11 : 2006 Edition: 5

Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"

Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

IEC 60079-26 : 2006 Edition: 2

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:
A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

HU/BKI/ExTR11 0004/00

Quality Assessment Report:

| HU/BKI/QAR09.0001/00 | | | |
|----------------------|--|--|--|
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |



IECEx Certificate of Conformity

Certificate No.:

IECEx BKI 11.0004X

Date of Issue:

2011-07-06

Issue No.: 0

Page 3 of 3

Schedule

EQUIPMENT:
Equipment and systems covered by this certificate are as follows:

The MULTICONT P**-2**- Ex is a universal process controller and display device suitable for supply 2-wire transmitters installed in hazardous area with intrinsic safety protection and suitable for displaying the measurement data of the transmitters on its graphic display. Connection with the transmitters is performed with HART communication interface. The device is an associated apparatus that can be installed and operated only outside of the hazardous area.

| See details in addendum to IECE | (BKI11.0004X. | |
|---------------------------------|-------------------------|--|
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| CONDITIONS OF CERTIFICAT | ON: YES as shown below: | |
| Ambient temperature range: | -20°C +50°C. | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

Annexe: Addendum to IECEx BKI 11.0004X.pdf

ADDENDUM TO IECEX CERTIFICATE OF CONFORMITY



IECEx BKI 11.0004 X

Page 1 of 2

1. Description

The **MULTICONT** P**-2**-* **Ex** is a universal process controller and display device suitable for supply 2-wire transmitters installed in hazardous area with intrinsic safety protection and suitable for displaying the measurement data of the transmitters on its graphic display. Connection with the transmitters is performed with HART communication interface. The device is an associated apparatus that can be installed and operated only outside of the hazardous area.

Optionally it can include max. 2 pieces of 4...20mA programmable analogue outputs, max. 5 pieces of programmable relays and one USER RS485 interface for another controller device which are installed outside of the hazardous area. MULTICONT PR*-2**-* Ex units include also a MODULE RS485 interface provide to expand the system with (separate wall mountable) Universal Interface Modules (UIM-s) installed outside of the hazardous area. This interface is not included in the MULTICONT PE*-2**-* Ex type instruments. The 4...20mA analogue outputs are galvanically isolated (also isolated from each other) and the USER and MODULE RS485 interfaces are galvanically isolated (also isolated from each other).

each other) and the USER and MODULE RS485 interfaces are galvanically isolated (also isolated from each other). 2. Type assortment MultiCONT P * * - 2 * * Code Enclosure Code Input Code Output Code Power supply Code Expansion For 1 HAR IP65 wall Standard 85 255 V AC Only display 1 0 1 R W enclosure For 2 HART IP65 wall 2 1 relay 24 V AC/DC 2 Not expandable 1 enclosure units C For 4 HART transparent 4 2 relays 2 85...255 V AC Ex 5 3 relays 3 24 V AC/DC Ex 6 IP65 wall enclosure + transparent D 4 relays 4 cover + logger 5 relays D 1x 4-20mA Analogue output 1 relay + 1x 4-20mA 5 Analogue output 2 relays + 1x 4-20mA 6 Analogue output Analogue output 4 relays + 1x 4-20mA Analogue output 2x 4-20mA Analogue G outputs 1 relay + 2x 4-20mA Н Analogue outputs 2 relays + 2x 4-20mA Analogue outputs Analogue outputs 4 relays + 2x 4-20mA RS 485 interface 1 relay + RS 485 interface 2 relays + RS 485 interface M 3 relays + RS 485 interface 4 relays + RS 485 interface 5 relays + RS 485 interface 1x 4-20mA Analogue B output +RS485 interface 1 relay + 1x 4-20mA R Analogue output + RS485 interface 2 relays + 1x 4-20mA Analogue output + RS485 C interface 3 relays + 1x 4-20mA Analogue output + RS485 S interface 4 relays + 1x 4-20mA Analogue output + RS485 T interface 2x 4-20mA + RS485 U interface 1 relay + 2x 4-20mA Analogue outputs + RS485 V interface 2 relays + 2x 4-20mA Analogue outputs + RS485 W interface 3 relays + 2x 4-20mA X Analogue outputs + RS485 interface 4 relays + 2x 4-20mA

Y

Analogue output + RS485

nterface

ADDENDUM TO IECEX CERTIFICATE OF CONFORMITY



Page 2 of 2

3 Electrical data

Power:

MultiCONT P**-2**-5 Ex: 85...255 V AC 50/60 Hz (12 VA);

MultiCONT P**-2**-6 Ex: 10,5...40 V DC (11 W);

10,5...28 V AC 50/60Hz (12 VA)

Signal output:

max. 2 pieces of 4...20mA programmable analogue outputs, max. 5 pieces of programmable relays, one USER RS485 interface

4 Ambient temperature range

Ambient temperature range:

-20°C ... +50°C.

5 Ingress protection

The enclosure provides a degree of protection IP 65 as per IEC 60529.

Special conditions for safe use

Drawings

| Title: | Drawing No.: | Rev. Level: | Date: |
|-------------------------------------|--------------------|-------------|-------------|
| Technical drawings | | | |
| Ex A-card parts placement drawing | PRW-210-5M-200-0X | 2. | 2011.04.12. |
| Ex T-card parts placement drawing | PRW-110-6M-220-0X | 0. | 2011.04.18. |
| Ex Z-card parts placement drawing | PRW-210-5M-251-0X | 1. | 2011.04.18. |
| Ex V-card parts placement drawing | PRW-110-5M-220-0X | 0. | 2011.03.02. |
| Ex A-PCB artwork L1 | PRW-210-5M-090-02 | 0. | 2011.07.01. |
| Ex A-PCB artwork L2 | PRW-210-5M-090-02 | 0. | 2011.07.01. |
| Ex T-PCB artwork | PRW-110-6M-090-01 | 0. | 2011.03.10. |
| Ex Z-PCB artwork | PRW-210-5M-090-04 | 0. | 2011.04.20. |
| Ex V-PCB artwork | PRW-110-050-090-03 | 0. | 2011.04.18. |
| Ex PRW-200 assembly drawing | PRW-110-5I-000-0X | 0. | 2011.04.21. |
| NTPE20090 assembly drawing | PRW-110-6M-221-0X | 0. | 2011.06.21. |
| NTPE20080 assembly drawing | PRW-110-5M-221-0X | 0. | 2011.06.21. |
| Ex Zener barrier assembly drawing | PRW-110-5M-250-0X | 0. | 2011.04.12. |
| Ex Separator plate | PRW-110-5M-000-01 | 0. | 2011.04.12. |
| Fuse sticker | PRW-110-1M-050-04 | 0. | 2011.04.12. |
| Ex label (Ex ia) | PRW-110-5M-050-03 | 0. | 2011.04.12. |
| Ex Wiring label | PRW-110-5M-050-02 | 0. | 2011.04.18. |
| Ex Data label | PRW-110-5M-050-0L | 0. | 2011.04.21. |
| Parts lists | | | |
| A-card Ex parts list | PRW-210-5M-200-0X | 1. | 2011.04.11. |
| T-card Ex parts list | PRW-110-6M-220-0X | 3. | 2011.04.11. |
| Z-card Ex parts list | PRW-210-5M-251-0X | 1. | 2011.04.11. |
| V-card Ex parts list | PRW-110-5M-220-0X | 2. | 2011.04.11. |
| Circuit Diagrams | | | |
| Ex A-card schematic circuit diagram | PRW-210-5M-200-0X | 1. | 2011.04.11. |
| Ex T-card schematic circuit diagram | PRW-110-6M-220-0X | 3. | 2011.03.10 |
| Ex Z-card schematic circuit diagram | PRW-210-5M-251-0X | 1. | 2011.04.11. |
| Ex V-card schematic circuit diagram | PRW-110-5M-220-0X | 2. | 2011.03.10. |